

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700005966F

Report Issued To : Green Cross Gemetocs Lab Pvt. Ltd. 4th Floor, Pushkar Annexe Complex, Naroda Bethak, Naroda, Ahmedabad, Gujarat-382330. , Ahmedabad, Gujarat Phone No : 7567219556 Email : gcnaroda@gmail.com	Test Report No : GTL/03260629006 Date of Receipt : 19/06/2026 Date of Issue : 29/06/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : N.M Sample Drawn By : Customer Date of Starting of Test : 19/06/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M Date of Completion : 29/06/2026
--	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.95	1	IS:3025(P-11)
2	Total Dissolved Solids, mg/l	Max.500	Max.2000	36	5	IS:3025(P-16)
3	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	12.20	1	IS:3025(P-21)

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : NM = Not Mentioned



For NABL Scope



Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD



Hemal Darji

Autho. Signatory

*** END OF REPORT ***