

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Blue Rock Hospitality Ventires Pvt. Ltd.
Ginger Hotel, HH51, Porbandar
Dwarka Highway, Dwarka, Gujarat
Phone No : 9979977606
Email : accountsdwarka@bluerock.in

Test Report No : GTL/03260729004/NS
Date of Receipt : 22/07/2026
Date of Issue : 29/07/2026
Customer's Ref. No : N.M

Sample Described as : S.T.P. Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic Bottle
Sample Condition : Satisfactory
Marking : N.M

Sampling Plan : as per GTL/GP/SOP/055
Sampling Date : 22.07.2026
Environ. Condition : Ambient

Sample Drawn By : Mr.Mukesh Patni (Representative of Gujarat Testlab Pvt Ltd)
Date of Starting of Test : 22/07/2026

Date of Completion : 29/07/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	6.85	IS:3025(P-11)
2	Total Dissolved Solids, mg/l	2567	IS:3025(P-16)
3	Total Suspended Solids mg/l	22	IS : 3025 (P-15) : 1984
4	Biological Oxygen Demand mg/l	10	IS:3025(P-44)
5	Chemical Oxygen Demand mg/l	34	IS : 3025 (P-58) : 2006
6	Residual Free Chlorine mg/l	B.L.Q.(Q.L.=0.05)	IS:3025(P-26)

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji
Autho. Signatory

*** END OF REPORT ***