



TC-5961

F-16,17, Madhavpura Market,
Shahibaug, Ahmedabad-380004
Ph. : 079-25626040, 25624821
M : 7486086091, 9601389681

E : gujlab@gmail.com/gujlab.info@gmail.com
Web : www.gujaratlaboratory.com

ULR-TC596126700006991F

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Shalby Hospital (Naroda).. S.No:679, Nr. Haridarsan Cross Road, Naroda,Ahmedabad., Ahmedabad, Gujarat Phone No : 9512049805 Email : quality.naroda@shalby.org	Test Report No : GTL/03260730002 Date of Receipt : 27/07/2026 Date of Issue : 30/07/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Liter Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : R.O Water Tank-1	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 27.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mayank solanki (Representative of Gujarat Testlab Pvt Ltd) Sampling Location : Shalby Hospital (Naroda).. Date of Starting of Test : 27/07/2026	Date of Completion : 30/07/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.84	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	21	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	1.68	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	5.74	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	0.97	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	4.20	1	IS:3025(P-21)

Biological Water

Test Report No : GTL/03260730002

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Q. L.	Test Method
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M. = Not Mentioned, B.L.Q. = Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar

Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji-Krishna Amin

Autho. Signatory