

ULR-TC596126700007036F

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To: **HCF Hospital**
Near Malav Talav, Before Rajwadu,
Jivraj Park, Ahmedabad,
Gujarat-380051, Ahmedabad,
Gujarat
Phone No : 9909942835
Email :
healthandcarefoundation@gmail.com

Test Report No : GTL/03260731001
Date of Receipt : 29/07/2026
Date of Issue : 31/07/2026
Customer's Ref. No : N.M

Sample Described as : Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic Bags
Sample Condition : Satisfactory
Marking : RO Water
Sampling Location : HCF Hospital
Sample Drawn By : Mr. Satish Rana (Representative of Gujarat Testlab Private Limited)
Date of Starting of Test : 29/07/2026
Sampling Plan : as per GTL/GP/SOP/046
Sampling Date : 29.07.2026
Environ. Condition : Ambient
Date of Completion : 31/07/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per Usp	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***