

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1


Report Issued To :	Sharanam Engineering and Automation Pvt. Ltd. H-405, Titanium City Centre, Nr. Sachine Tower 100 Ft. Anandnagar Road, Satellite-380016, Ahmedabad, Gujarat Phone No : 7048562260 Email : dhairyashara300@gmail.com	Test Report No : GTL/03260731007/NS Date of Receipt : 27/07/2026 Date of Issue : 31/07/2026 Customer's Ref. No : N.M
--------------------	--	---

Sample Described as	: Water.	Mfg. Date	: N.M.
Sample Qty	: 2.0 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M.
Sample Condition	: Satisfactory		
Marking	: Sample : Makeup Water		
Sample Drawn By	: Customer		
Date of Starting of Test	: 27/07/2026	Date of Completion	: 31/07/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Residues and Contaminants in Water			
1	Iron (as Fe) mg/I	B.L.Q. (Q.L.=0.005)	IS:3025(P-65)
Water			
2	Nitrate (as NO3) mg/I	6.23	IS:3025(P-34)

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Mamta Bhavsar
Reviewed By



For Verification


Hemal Darji
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Sharanam Engineering and Automation Pvt. Ltd.
H-405, Titanium City Centre, Nr.
Sachine Tower 100 Ft. Anandnagar
Road, Satellite-380016, Ahmedabad,
Gujarat
Phone No : 7048562260
Email : dhairyashara300@gmail.com

Test Report No : GTL/03260731008/NS
Date of Receipt : 27/07/2026
Date of Issue : 31/07/2026
Customer's Ref. No : N.M

Sample Described as : Water.
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic Bottle
Sample Condition : Satisfactory
Marking : Sample : Chiller Water


Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 27/07/2026

Date of Completion : 31/07/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Residues and Contaminants in Water			
1	Iron (as Fe) mg/I	0.28	IS:3025(P-65)
Water			
2	Nitrate (as NO3) mg/I	7.02	IS:3025(P-34)

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only


Mamta Bhavsar


Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji

Autho. Signatory