

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700007063F

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260731038 Date of Receipt : 28/07/2026 Date of Issue : 31/07/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : SAC	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Sampling Location : The Ahmedabad University Date of Starting of Test : 28/07/2026	Date of Completion : 31/07/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.54	1	IS:3025(P-11)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
4	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
5	Total Dissolved Solids, mg/l	Max.500	Max.2000	85	5	IS:3025(P-16)
6	Chloride (as Cl), mg/l	Max.250	Max. 1000	27.79	0.5	IS:3025(P-32)
7	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
8	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
9	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	29.40	1	IS:3025(P-21)
10	Residual Free Chlorine mg/l	Min. 0.2	Max.1.0	B.L.Q.	0.05	IS:3025(P-26)
Residues and Contaminants in Water						
11	Iron (as Fe) mg/l	Max. 0.3	No Relaxation	B.L.Q.	0.005	IS:3025 (P-65) 2014
Biological Water						
1	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260731038

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory