

TEST REPORT

ULR-TC596126700007070F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Das Hari Hotels Private Limited 73,Shardas AAM Bagan, Near PakwanFour Road Opp.Sindhuhavan, S.G.Highway,Bodakdev-380054, Ahmedabad, Gujarat Phone No : 9558006373 Email : shardasaambagan@gmail.com	Test Report No : GTL/03260801002 Date of Receipt : 29/07/2026 Date of Issue : 01/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Glass Bottle Sample Condition : Satisfactory Marking : Resturant : Mango Neem Sample Drawn By : Customer Date of Starting of Test : 29/07/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M. Date of Completion : 01/08/2026
---	--

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.13	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max. 500	Max 2000	195	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	42.08	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	15.88	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	14.61	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	163.80	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016

Test Report No : GTL/03260801002

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
2	E coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar
Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji-Krishna Amin
Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***