

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007075F

Page 1 of 1

Report Issued To : The Fern Sattva Resort Polo Forest
Dhorivav, P.O. Vijanagar,
Ahmedabad, Gujarat
Phone No : 7485999666
Email :
om.tf.poloforest@fernhotels.com

Test Report No : GTL/03260801008
Date of Receipt : 20/07/2026
Date of Issue : 01/08/2026
Customer's Ref. No : N.M

Sample Described as : Water.
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic Bottle
Sample Condition : Satisfactory
Marking : cooling Tower

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M

Sample Drawn By : Customer
Date of Starting of Test : 20/07/2026

Date of Completion : 01/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02


Page 1 of 1

Report Issued To :	The Fern Sattva Resort Polo Forest Dhorivav, P.O. Vijanagar, Ahmedabad, Gujarat Phone No : 7485999666 Email : om.tf.poloforest@fernhotels.com	Test Report No	: GTL/03260801008/NS
		Date of Receipt	: 20/07/2026
		Date of Issue	: 01/08/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water.	Mfg. Date	: N.M.
Sample Qty	: 2 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: cooling Tower		
Sample Drawn By	: Customer	Date of Completion	: 01/08/2026
Date of Starting of Test	: 20/07/2026		

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	6.84	IS:3025(P-11)
2	Total Dissolved Solids, mg/l	490	IS:3025(P-16)
3	Total Alkalinity as Calcium Carbonate , mg/l	43.93	IS:3025(P-23)
4	Total Hardness (as CaCO ₃), mg/l	54.38	IS:3025(P-21)

Note : NM = Not Mentioned, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji
Autho. Signatory