

TEST REPORT

ULR-TC596126700007079F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Uma Beverages New S.No : 373, Rancharda, Gandhinagar, Gandhinagar, Gujarat Phone No : 8460277483 Email : umabeverages.01@gmail.com	Test Report No : GTL/03260801012 Date of Receipt : 29/07/2026 Date of Issue : 01/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Yellow Water Sample Drawn By : Customer Date of Starting of Test : 29/07/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M. Date of Completion : 01/08/2026
---	--

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
2	pH at 25 Deg C	6.5 to 8.5	No Relaxation	10.24	1	IS:3025(P-11)
3	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
4	Total Dissolved Solids, mg/l	Max.500	Max.2000	169	5	IS:3025(P-16)
5	Calcium (as Ca), mg/l	Max.75	Max.200	5.05	0.1	IS:3025(P-40)
6	Chloride (as Cl), mg/l	Max.250	Max. 1000	75.40	0.5	IS:3025(P-32)
7	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
8	Magnesium (as Mg), mg/l	Max. 30	Max. 100	2.90	0.1	IS:3025(P-46)
9	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
10	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
11	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
12	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	21.0	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260801012

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found DOES NOT CONFORM as per IS:10500-2012 with Amendment NO-4 for the tested parameters

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar
Mamta Bhavsar

Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji-Krishna Amin
Hemal Darji-Krishna Amin

Autho. Signatory