

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007110F

Page 1 of 1

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803005
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Sample :Cooling Tower Water (AHU-05)

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 23/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

T. Thakor
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007111F

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803004
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Sample :Cooling Tower Water (AHU-06)

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 23/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007112F

Page 1 of 1

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803006
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**

Sample Qty : 2.0 Ltr

Packing Mode : Sample Packed in Plastic
Bottle

Sample Condition : Satisfactory

Marking : Sample : Cooling Tower Water (AHU-17)

Mfg. Date : N.M.

Exp. Date : N.M.

B.No : N.M.

Sample Drawn By : Customer

Date of Starting of Test : 23/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Trupti
Trupti Thakor
Autho. Signatory

**TEST REPORT**

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007113F

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803007
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Sample :Cooling Tower Water (CCT-01)

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 23/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Trupti
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007114F

Page 1 of 1

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803008
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : Water.
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic Bottle
Sample Condition : Satisfactory
Marking : Sample :Cooling Tower Water (PCT-01)
Sample Drawn By : Customer
Date of Starting of Test : 23/07/2026
Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.
Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Trupti
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : **Green Shield Laboratory LLP**
26, Shubham Industrial Park, Opp.
Cozy Hotel New Road Near Vaishali
Nagar, Shahwadi, Narol-382405,
Ahmedabad, Gujarat
Phone No : 8905236536
Email : greenshieldlab@gmail.com

Test Report No : GTL/03260803005/NS
Date of Receipt : 23/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : Water.
Sample Qty : 2.0 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Sample :Cooling Tower Water (AHU-05)

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 23/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Pseudomonas Aeruginosa /250 ml	Absent	IS:13428(Ann-D)
2	Total Coliform per 100 ml	Absent	IS:15185:2016
3	Total Bacterial Count cfu/ml	10 cfu	IS:5402 (P-1): 2021
4	E.coli per 100 ml	Absent	IS: 15185:2016

Note : NM = Not Mentioned, Customer requested for the above test only

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Trupti
Trupti Thakor
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Green Shield Laboratory LLP 26, Shubham Industrial Park, Opp. Cozy Hotel New Road Near Vaishali Nagar, Shahwadi, Narol-382405, Ahmedabad, Gujarat Phone No : 8905236536 Email : greenshieldlab@gmail.com	Test Report No : GTL/03260803004/NS Date of Receipt : 23/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water. Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Sample :Cooling Tower Water (AHU-06)	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M.
Sample Drawn By : Customer Date of Starting of Test : 23/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Pseudomonas Aeruginosa /250 ml	Absent	IS:13428(Ann-D)
2	Total Coliform per 100 ml	Absent	IS:15185:2016
3	Total Bacterial Count cfu/ml	15 cfu	IS:5402 (P-1): 2021
4	E.coli per 100 ml	Absent	IS: 15185:2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Green Shield Laboratory LLP 26, Shubham Industrial Park, Opp. Cozy Hotel New Road Near Vaishali Nagar, Shahwadi, Narol-382405, Ahmedabad, Gujarat Phone No : 8905236536 Email : greenshieldlab@gmail.com	Test Report No : GTL/03260803006/NS Date of Receipt : 23/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water. Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Sample :Cooling Tower Water (AHU-17)	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M.
Sample Drawn By : Customer Date of Starting of Test : 23/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Pseudomonas Aeruginosa /250 ml	Absent	IS:13428(Ann-D)
2	Total Coliform per 100 ml	Absent	IS:15185:2016
3	Total Bacterial Count cfu/ml	18 cfu	IS:5402 (P-1): 2021
4	E.coli per 100 ml	Absent	IS: 15185:2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1


Report Issued To : Green Shield Laboratory LLP 26, Shubham Industrial Park, Opp. Cozy Hotel New Road Near Vaishali Nagar, Shahwadi, Narol-382405, Ahmedabad, Gujarat Phone No : 8905236536 Email : greenshieldlab@gmail.com	Test Report No : GTL/03260803007/NS Date of Receipt : 23/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water. Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Sample :Cooling Tower Water (CCT-01)	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M.
Sample Drawn By : Customer Date of Starting of Test : 23/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Pseudomonas Aeruginosa /250 ml	Absent	IS:13428(Ann-D)
2	Total Coliform per 100 ml	Absent	IS:15185:2016
3	Total Bacterial Count cfu/ml	20 cfu	IS:5402 (P-1): 2021
4	E.coli per 100 ml	Absent	IS: 15185:2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Ketul Padhiyar
Reviewed By



For Verification


Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Green Shield Laboratory LLP 26, Shubham Industrial Park, Opp. Cozy Hotel New Road Near Vaishali Nagar, Shahwadi, Narol-382405, Ahmedabad, Gujarat Phone No : 8905236536 Email : greenshieldlab@gmail.com	Test Report No : GTL/03260803008/NS Date of Receipt : 23/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water.	Mfg. Date : N.M.
Sample Qty : 2.0 Ltr	Exp. Date : N.M.
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M.
Sample Condition : Satisfactory	
Marking : Sample :Cooling Tower Water (PCT-01)	
Sample Drawn By : Customer	
Date of Starting of Test : 23/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Pseudomonas Aeruginosa /250 ml	Absent	IS:13428(Ann-D)
2	Total Coliform per 100 ml	Absent	IS:15185:2016
3	Total Bacterial Count cfu/ml	15 cfu	IS:5402 (P-1): 2021
4	E.coli per 100 ml	Absent	IS: 15185:2016

Note : NM = Not Mentioned, Customer requested for the above test only

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

T. Thakor
Trupti Thakor
Autho. Signatory