

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Hal Offshore Limited Kariyal Village, Vadpura road, ONGC GGs ETP& WIP Plant, Nandasan, Mehsana, Gujarat Phone No : 7206836104 Email : omprakash@haloffshore.com	Test Report No : GTL/03260803016/NS Date of Receipt : 29/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	---

Sample Described as : Water.	Mfg. Date : N.M.
Sample Qty : 500 ml	Exp. Date : N.M.
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M.
Sample Condition : Satisfactory	
Marking : Sample Name : WIP Tank	
Sample Drawn By : Customer	
Date of Starting of Test : 29/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological			
Water			
1	General Aerobic Bacteria Count per ml	15 cfu	IS:5402(P-1):2021
2	Sulphide Reducing Bacteria Count/ml	Absent	IS:13428(Ann-C):2005

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD

Ketul Padhiyar

Reviewed By



For Verification

*** END OF REPORT ***

Trupti Thakor

Autho. Signatory