

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007119F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803017 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : GICT	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope



Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007120F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803018 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : Sport Complex	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

g.o.m.o.m.
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007121F

Page 1 of 1

Report Issued To : The Ahmedabad University
2, AES Bungalow, Commerce Six Road,
Navrangpura, Ahmedabad, Gujarat
Phone No : 7331136282
Email : pawan.kumar@ahduni.edu.in

Test Report No : GTL/03260803019
Date of Receipt : 28/07/2026
Date of Issue : 03/08/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water

Sample Qty : 500 ml

Packing Mode : Sample Packed in Plastic
Bottle

Sample Condition : Satisfactory

Marking : Location : Bionest

Sampling Plan : as per GTL/GP/SOP/055

Sampling Date : 28.07.2026

Environ. Condition : Ambient

Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd)

Date of Starting of Test : 28/07/2026

Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Krishna Amin
Autho. Signatory

**TEST REPORT**

Doc. No : GTL/D/7.5/02

ULR-TC596126700007122F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803020 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water	Sampling Plan : as per GTL/GP/SOP/055
Sample Qty : 500 ml	Sampling Date : 28.07.2026
Packing Mode : Sample Packed in Plastic Bottle	Environ. Condition : Ambient
Sample Condition : Satisfactory	
Marking : Location : BRL	
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd)	
Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned. Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

g.m.o.m.
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007123F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803021 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : SAS Building	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

S. Krishna
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007124F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803022 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : Amsom Heritage	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

S. Amin
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007125F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803023 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : CHM	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapad Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

S. M. Amin
Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007126F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803024 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : BK Building	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul Padhiyar
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

Krishna Amin
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007127F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803025 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : University Office	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

Krishna Amin
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007128F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803026 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : Venture Studio	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Krishna Amin
Krishna Amin
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007129F

Page 1 of 1

Report Issued To : The Ahmedabad University 2, AES Bungalow, Commerce Six Road, Navrangpura, Ahmedabad, Gujarat Phone No : 7331136282 Email : pawan.kumar@ahduni.edu.in	Test Report No : GTL/03260803027 Date of Receipt : 28/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : SCS	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 28.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Date of Starting of Test : 28/07/2026	Date of Completion : 03/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

K. M. Amin
Krishna Amin
Autho. Signatory

*** END OF REPORT ***