

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700007151F

Report Issued To : Shivaay Hydro Solutions B/06, Swagat Rainforest-2, Opp. Swaminarayan Dham, Kudasan-382421, Gandhinagar, Gujarat Phone No : 7984089390 Email : shivaayhydrosolutions07@gmail.com	Test Report No : GTL/03260803049 Date of Receipt : 30/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Nageshwari Farm Vasanjanda-Before Treted Water	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M
Sample Drawn By : Customer Date of Starting of Test : 30/07/2026	Date of Completion : 03/08/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.85	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	3222	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	223.04	0.1	IS:3025(P-40)
8	Magnesium (as Mg), mg/l	Max. 30	Max. 100	143.66	0.1	IS:3025(P-46)
9	Sulphate (as SO ₄), mg/l	Max. 200	Max. 400	30.23	0.5	IS:3025(P-24 Sec-1)
10	Total Alkalinity as Calcium Carbonate (HCO ₃) mg/l	Max. 200	Max. 600	473.76	0.5	IS:3025(P-23)

Test Report No : GTL/03260803049

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found DOES NOT CONFORM as per IS:10500-2012 with Amendment NO-4 for the tested parameters

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Shivaay Hydro Solutions B/06, Swagat Rainforest-2, Opp. Swaminarayan Dham, Kudasani-382421, Gandhinagar, Gujarat Phone No : 7984089390 Email : shivaayhydrosolutions07@gmail.com	Test Report No : GTL/03260803049/NS Date of Receipt : 30/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Nageshwari Farm Vasanjanda-Before Treated Water Sample Drawn By : Customer Date of Starting of Test : 30/07/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M. Date of Completion : 03/08/2026
--	--

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Chloride (as Cl), mg/l	Max.250	Max. 1000	1712.23	0.5	IS:3025(P-32)
2	Total Hardness (as CaCO ₃), mg/l	Max. 200	Max. 600	1165.50	1	IS:3025(P-21)

Remark : Sample Found DOES NOT CONFORM as per IS:10500-2012 with Amendment NO-4 for the tested parameters

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji
Autho. Signatory

*** END OF REPORT ***