



TC-5961

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007152F

Report Issued To : Sterling Ram Krishna Speciality Hospital Plot Health Centre, Ward 10-B"C", Nr. YMCA, Opp.IFFCO Colony, Gandhidham, Kutch, Gujarat Phone No : 7203040484 Email : maintenance.gandhidham@sterlinghositals.com	Test Report No : GTL/03260803050 Date of Receipt : 30/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : DM Water Sample Drawn By : Customer Date of Starting of Test : 30/07/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M. Date of Completion : 03/08/2026
---	--

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Total Dissolved Solids, mg/l	Max.500	Max.2000	<5	5	IS:3025(P-16)
2	Chloride (as Cl), mg/l	Max.250	Max. 1000	B.L.Q.	0.5	IS:3025(P-32)
3	Total Hardness (as CaCO ₃), mg/l	Max. 200	Max. 600	B.L.Q.	0.5	IS:3025(P-21)

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT/TESTLAB PVT. LTD

Hemal Darji
Autho. Signatory

*** END OF REPORT ***