

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700007156F

Report Issued To : Sterling Ram Krishna Speciality Hospital Plot Health Centre, Ward 10-B"C", Nr. YMCA, Opp.IFFCO Colony, Gandhidham, Kutch, Gujarat Phone No : 7203040484 Email : maintenance.gandhidham@sterlinghos pitals.com	Test Report No : GTL/03260803054 Date of Receipt : 30/07/2026 Date of Issue : 03/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Bore Water	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M
Sample Drawn By : Customer Date of Starting of Test : 30/07/2026	Date of Completion : 03/08/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max 5.0	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.94	1	IS:3025(P-11)
4	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
5	Calcium (as Ca), mg/l	Max.75	Max.200	132.98	0.1	IS:3025(P-40)
6	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
7	Magnesium (as Mg), mg/l	Max. 30	Max. 100	126.62	0.1	IS:3025(P-46)
8	Manganese (as Mn), mg/l	Max. 0.1	Max. 0.3	B.L.Q.	0.005	IS:3025(P-65)
9	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	25.36	1	IS:3025(P-34)
10	Sulphate (as SO4), mg/l	Max. 200	Max. 400	55.32	1.0	IS:3025(P-24 Sec-1)
Residues and Contaminants in Water						
11	Iron (as Fe) mg/l	Max. 0.3	No Relaxation	B.L.Q.	0.005	IS:3025(P-65)
12	Cadmium (as Cd), mg/l	Max. 0.003	No Relaxation	B.L.Q.	0.002	IS:3025(P-65)
13	Lead (as Pb), mg/l	Max. 0.01	No Relaxation	B.L.Q.	0.005	IS:3025(P-65)
14	Total Arsenic (as As) mg/l	Max. 0.01	Max. 0.05	B.L.Q.	0.005	IS:3025(P-65)
15	Total Chromium (as Cr) mg/l	Max. 0.05	No Relaxation	B.L.Q.	0.01	IS:3025(P-65)

Biological Water

1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	--	IS: 15185:2016
---	---------------------------	-------------------------	-------------------------	--------	----	----------------

Test Report No : GTL/03260803054

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	--	IS: 15185:2016

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin

Autho. Signatory