

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007175F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804018 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water	Sampling Plan : as per GTL/GP/SOP/055
Sample Qty : 500 ml	Sampling Date : 30.07.2026
Packing Mode : Sample Packed in Plastic Bottle	Environ. Condition : Ambient
Sample Condition : Satisfactory	
Marking : Location : Central Dinning Hall	
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd)	
Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007176F

Page 1 of 1

Report Issued To : Occupational Health Center
C/O. Reliance Industries Limited,
Dahej Manufacturing Division (DMD)
Dahej, Tal; Vagra, Bharuch, Gujarat
Phone No : 6353700724
Email : Sahajanand.Thakar@ril.com

Test Report No : GTL/03260804019
Date of Receipt : 30/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 500 ml
Packing Mode : Sample Packed in Plastic Bottle
Sample Condition : Satisfactory
Marking : Location : Project Dinning Hall

Sampling Plan : as per GTL/GP/SOP/055
Sampling Date : 30.07.2026
Environ. Condition : Ambient

Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd)
Date of Starting of Test : 30/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007177F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804020 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water	Sampling Plan : as per GTL/GP/SOP/055
Sample Qty : 500 ml	Sampling Date : 30.07.2026
Packing Mode : Sample Packed in Plastic Bottle	Environ. Condition : Ambient
Sample Condition : Satisfactory	
Marking : Location : PTA-07 Afcons	
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd)	
Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketui
Ketui Padhiyar
Reviewed By



For Verification

B. Amin
Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007178F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804021 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : Ethane Store	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007182F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804025 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : AFS Medical Centre	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007183F

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804026 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--


Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : STS Guest House	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007184F

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804027 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--


Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Location : Kaveri Township	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007185F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804028 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water	Sampling Plan : as per GTL/GP/SOP/055
Sample Qty : 500 ml	Sampling Date : 30.07.2026
Packing Mode : Sample Packed in Plastic Bottle	Environ. Condition : Ambient
Sample Condition : Satisfactory	
Marking : Location : Saryu Township	
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd)	
Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007186F

Report Issued To : **Occupational Health Center**
C/O. Reliance Industries Limited,
Dahej Manufacturing Division (DMD)
Dahej, Tal; Vagra, Bharuch, Gujarat
Phone No : 6353700724
Email : Sahajanand.Thakar@ril.com

Test Report No : GTL/03260804029
Date of Receipt : 30/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : **Drinking Water**
Sample Qty : 500 ml
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Location : Yamuna Township

Sampling Plan : as per GTL/GP/SOP/055
Sampling Date : 30.07.2026
Environ. Condition : Ambient

Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd)
Date of Starting of Test : 30/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification


Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700007187F

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804030 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Services Water, Location : Hotel Luxury	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul

Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Krishna Amin

Krishna Amin
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007188F

Page 1 of 1

Report Issued To : Occupational Health Center C/O. Reliance Industries Limited, Dahej Manufacturing Division (DMD) Dahej, Tal; Vagra, Bharuch, Gujarat Phone No : 6353700724 Email : Sahajanand.Thakar@ril.com	Test Report No : GTL/03260804031 Date of Receipt : 30/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : R.O.Water, Location : Hotel Luxury	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 30.07.2026 Environ. Condition : Ambient
Sample Drawn By : Mr.Mukesh Patani (Representative of Gujarat Testlab Pvt Ltd) Date of Starting of Test : 30/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

80/08/26
Krishna Amin
Autho. Signatory

*** END OF REPORT ***