

ULR-TC596126700007203F

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Torrent Power Limited. Sabarmati Generation Station,Nr. Chimanbhai patel Bridge Sabarmati,, Ahmedabad, Gujarat Phone No : 9427326816 Email : satishpanchal@torrentpower.com	Test Report No : GTL/03260804046 Date of Receipt : 21/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Water.	Mfg. Date : N.M
Sample Qty : 2 Ltr	Exp. Date : N.M
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M
Sample Condition : Satisfactory	
Marking : D-Cooling Tower Water Dated : 21.07.2026	
Sample Drawn By : Customer	
Date of Starting of Test : 21/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological			
Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : **Torrent Power Limited.**
Sabarmati Generation Station,Nr.
Chimanbhai patel Bridge Sabarmati,,
Ahmedabad, Gujarat
Phone No : 9427326816
Email :
satishpanchal@torrentpower.com

Test Report No : GTL/03260804046/NS
Date of Receipt : 21/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : D-Cooling Tower Water Dated : 21.07.2026

Mfg. Date : N.M
Exp. Date : N.M
B.No : N.M


Sample Drawn By : Customer
Date of Starting of Test : 21/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological			
Water			
1	Sulphide Reducing Bacteria Count/ml	<1 cfu	IS:13428(Ann-C):2005
2	Total Bacterial Count cfu/ml	20 cfu	IS:5402 (P-1): 2021

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Ketul Padhiyar
Reviewed By



For Verification


Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007204F

Page 1 of 1

Report Issued To : **Torrent Power Limited.**
Sabarmati Generation Station,Nr.
Chimanbhai patel Bridge Sabarmati,,
Ahmedabad, Gujarat
Phone No : 9427326816
Email :
satishpanchal@torrentpower.com

Test Report No : GTL/03260804047
Date of Receipt : 21/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : E-Cooling Tower Water Dated : 21.07.2026

Mfg. Date : N.M
Exp. Date : N.M
B.No : N.M

Sample Drawn By : Customer
Date of Starting of Test : 21/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope


Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To :	Torrent Power Limited. Sabarmati Generation Station, Nr. Chimanbhai Patel Bridge Sabarmati,, Ahmedabad, Gujarat Phone No : 9427326816 Email : satishpanchal@torrentpower.com	Test Report No	: GTL/03260804047/NS
		Date of Receipt	: 21/07/2026
		Date of Issue	: 04/08/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water.	Mfg. Date	: N.M
Sample Qty	: 2 Ltr	Exp. Date	: N.M
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: E-Cooling Tower Water Dated : 21.07.2026		
Sample Drawn By	: Customer	Date of Completion	: 04/08/2026
Date of Starting of Test	: 21/07/2026		

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Sulphide Reducing Bacteria Count/ml	< 1 cfu	IS:13428(Ann-C):2005
2	Total Bacterial Count cfu/ml	22 cfu	IS:5402 (P-1): 2021

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD

Ketul Padhiyar

Reviewed By



For Verification

*** END OF REPORT ***

Trupti Thakor

Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007205F

Page 1 of 1

Report Issued To :	Torrent Power Limited. Sabarmati Generation Station,Nr. Chimanbhai patel Bridge Sabarmati,, Ahmedabad, Gujarat Phone No : 9427326816 Email : satishpanchal@torrentpower.com	Test Report No	: GTL/03260804048
		Date of Receipt	: 21/07/2026
		Date of Issue	: 04/08/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water.	Mfg. Date	: N.M
Sample Qty	: 2 Ltr	Exp. Date	: N.M
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: F-Cooling Tower Water Dated : 21.07.2026		
Sample Drawn By	: Customer	Date of Completion	: 04/08/2026
Date of Starting of Test	: 21/07/2026		

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Tripti
Tripti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : **Torrent Power Limited.**
Sabarmati Generation Station, Nr.
Chimanbhai Patel Bridge Sabarmati,,
Ahmedabad, Gujarat
Phone No : 9427326816
Email :
satishpanchal@torrentpower.com

Test Report No : GTL/03260804048/NS
Date of Receipt : 21/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : F-Cooling Tower Water Dated : 21.07.2026

Mfg. Date : N.M
Exp. Date : N.M
B.No : N.M


Sample Drawn By : Customer
Date of Starting of Test : 21/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Sulphide Reducing Bacteria Count/ml	<1 cfu	IS:13428(Ann-C):2005
2	Total Bacterial Count cfu/ml	40 cfu	IS:5402 (P-1): 2021

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Ketul Padhiyar
Reviewed By



For Verification

*** END OF REPORT ***


Trupti Thakor
Autho. Signatory

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700007206F

Page 1 of 1

Report Issued To : Torrent Power Limited. Sabarmati Generation Station,Nr. Chimanbhai patel Bridge Sabarmati,, Ahmedabad, Gujarat Phone No : 9427326816 Email : satishpanchal@torrentpower.com	Test Report No : GTL/03260804049 Date of Receipt : 21/07/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Water.	Mfg. Date : N.M
Sample Qty : 2 Ltr	Exp. Date : N.M
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M
Sample Condition : Satisfactory	
Marking : Cafeteria Drinking Water Dated : 21.07.2026	
Sample Drawn By : Customer	
Date of Starting of Test : 21/07/2026	Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Not Detected	ISO:11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only



For NABL Scope

Ketui
Ketui Padhiyar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Tripti
Tripti Thakor
Autho. Signatory

*** END OF REPORT ***

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : **Torrent Power Limited.**
Sabarmati Generation Station,Nr.
Chimanbhai patel Bridge Sabarmati,,
Ahmedabad, Gujarat
Phone No : 9427326816
Email :
satishpanchal@torrentpower.com

Test Report No : GTL/0326080409/NS
Date of Receipt : 21/07/2026
Date of Issue : 04/08/2026
Customer's Ref. No : N.M

Sample Described as : **Water.**

Sample Qty : 2 Ltr

Packing Mode : Sample Packed in Plastic
Bottle

Sample Condition : Satisfactory

Marking : Cafeteria Drinking Water Dated : 21.07.2026

Mfg. Date : N.M

Exp. Date : N.M

B.No : N.M

Sample Drawn By : Customer


Date of Starting of Test : 21/07/2026

Date of Completion : 04/08/2026

Sr No	Quality Characteristics	Result	Test Method
Biological			
Water			
1	Sulphide Reducing Bacteria Count/ml	<1 cfu	IS:13428(Ann-C):2005
2	Total Bacterial Count cfu/ml	45 cfu	IS:5402 (P-1): 2021

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Ketul Padhiyar

Reviewed By



For Verification

*** END OF REPORT ***


Trupti Thakor

Autho. Signatory