

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Sterling Accuris Wellness Pvt. Ltd. Sankalp Square II, Old Sharda Mandir Cross roads B.S Jalaram Mandir railway Crossing, Ellisbridge,, Ahmedabad, Gujarat Phone No : 9726753939 Email : report.accuris@gmail.com	Test Report No : GTL/03260804052/NS Date of Receipt : 01/08/2026 Date of Issue : 04/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water. Sample Qty : 500 ml Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Lab ID : 072664005082, Specimen Id : 97072664005082, Collection Date : 31-July-2026 (13:06), Patient Name : R.O Water (U/), Ref By : HCG Hospital Ahmedabad Sample Drawn By : Customer Date of Starting of Test : 01/08/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M. Date of Completion : 04/08/2026
---	--

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Water			
1	Odour	Agreeable	IS:3025(P-5)
2	pH at 25 Deg C	7.90	IS:3025(P-11)
3	Taste	Agreeable	IS:3025(P-7 & 8)
4	Turbidity, NTU	<0.1	IS:3025(P-10)
5	Total Dissolved Solids, mg/l	30	IS:3025(P-16)
6	Chloride (as Cl), mg/l	1.82	IS:3025(P-32)
7	Magnesium (as Mg), mg/l	5.01	IS:3025(P-46)
8	Sulphate (as SO ₄), mg/l	B.L.Q.(Q.L.=1.0)	IS:3025(P-24 Sec-1)
9	Total Alkalinity as Calcium Carbonate, mg/l	15.04	IS:3025(P-23)
10	Total Hardness (as CaCO ₃), mg/l	8.40	IS:3025(P-21)
11	Calcium (as Ca), mg/l	3.36	IS : 3025 (P-40):1991
12	Colour, Hazen Unit	<1	IS:3025(P-4)


Test Report No : GTL/03260804052/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Customer requested for the above test only


Mamta Bhavsar

Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD



Hemal Darji

Autho. Signatory