

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : H M Water Tech. A/1114 K.P.Epitome, Nr.DAV School Makarba, Ahmedabad, Gujarat Phone No : 9904378778 Email : accounts1@hmwatertech.co.in	Test Report No : GTL/03260811022/NS Date of Receipt : 06/08/2026 Date of Issue : 11/08/2026 Customer's Ref. No : N.M
--	---

Sample Described as : Water. Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Site Name : Reliable Dye Chem Pvt Ltd	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M
Sample Drawn By : Customer Date of Starting of Test : 06/08/2026	Date of Completion : 11/08/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	5.20	IS:3025(P-11)
2	Total Dissolved Solids, mg/l	137820	IS:3025(P-16)
3	Chloride (as Cl), mg/l	17834.89	IS:3025(P-32)
4	Sulphate (as SO ₄), mg/l	382	IS:3025(P-24 Sec-1)
5	Total Hardness (as CaCO ₃), mg/l	4700	IS:3025(P-21)
6	Total Suspended Solids mg/l	19	IS:3025(P-17)
7	Calcium Hardness (as Ca), mg/l	2846.68	IS:3025(P-40)
8	Chemical Oxygen Demand mg/l	523	IS:3025(P-58)
9	Reactive Silica (as si) mg/l	65	APHA 24th Edition

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***


Hemal Darji
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.