

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To :	Shri Metal Connect LLP 02, Basement, Agrawal Mall , Opp. Bhagwat Vidhyapith , Sarkhej Gadhinagar Highway , Sola, Ahmedabad, Gujarat Phone No : 8780646901 Email : testing@smclab.in	Test Report No	: GTL/03260811043/NS
		Date of Receipt	: 05/08/2026
		Date of Issue	: 11/08/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water.	Mfg. Date	: N.M.
Sample Qty	: 2 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: Lab ID : SMC/TR/26/0803/P0122		
Sample Drawn By	: Customer	Date of Completion	: 11/08/2026
Date of Starting of Test	: 05/08/2026		

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	7.51	IS:3025(P-11)
2	Turbidity, NTU	<0.1	IS:3025(P-10)
3	Total Dissolved Solids, mg/l	592	IS:3025(P-16)
4	Chloride (as Cl), mg/l	281.69	IS:3025(P-32)
5	Total Hardness (as CaCO ₃), mg/l	109.85	IS:3025(P-21)
6	Ammonia (as Total Ammonia-N) mg/l	B.L.Q. (Q.L.=0.05)	IS:3025(P-34)
7	Total Suspended Solids mg/l	<5	IS:3025(P-17)
8	Conductivity at 25 C us/cm	902.5	IS:3025(P-14)
9	Dissolved Oxygen mg/l	2.1	APHA 24th Edition
10	Salinity %	0.058	GL/SOP/C-269

Test Report No : GTL/03260811043/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji
Autho. Signatory

Disclaimer Note

*** END OF REPORT ***
(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated. (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.