

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700017725F

Report Issued To: FORTUNE STATUE OF UNITY EKTANAGAR Statut of Unity Main Road, Near.Rewa Bhavan, Ektanagar,Kevadia, Dist.: Narmada-393151, Narmada, Gujarat Phone No : +91 86002 99292 Email : ce.kevsou@fortunehotels.in	Test Report No : GTL/03260819053 Date of Receipt : 12/08/2026 Date of Issue : 19/08/2026 Customer's Ref. No : N.M
--	--

Sample Described as Sample Qty Packing Mode Sample Condition Marking Sampling Location Sample Drawn By Date of Starting of Test	: Swimming Pool Water : 2 Ltr : Sample Packed in Plastic Bottle : Satisfactory : N.M : FORTUNE STATUE OF UNITY EKTANAGAR : Mr. Hardev (Representative of Gujarat Testlab Private Limited) : 12/08/2026	Sampling Plan Sampling Date Environ. Condition	: as per GTL/GP/SOP/055 : 12.08.2026 : Ambient
	Date of Completion : 19/08/2026		

Sr No	Quality Characteristics	Result	Test Method	Specific Requirement as per IS:3328
Chemical Water				
1	pH at 25 Deg C	8.25	IS:3025(P-11)	7.5 to 8.5
2	Total Alkalinity as Calcium Carbonate, mg/l	325.60	IS:3025(P-23)	50 to 500
3	Aluminium (as Al) mg/l	B.L.Q.(Q.L.=0.01)	IS 3025 (P-55) : 2003	Max. 0.1
4	Total Dissolved Solids, mg/l	525	IS : 3025 (P-16) 2002	Max. 1500
5	Chloride (as Cl), mg/l	97.14	IS : 3025 (P-32) : 1988, Reaff-1999	Max. 500
6	Iron (as Fe) mg/l	B.L.Q. (Q.L.=0.005)	IS:3025(P-53)	Max. 0.1
7	Turbidity, NTU	<0.1	IS:3025(P-10)	Max. 10.0
8	Total Hardness (as CaCO ₃), mg/l	91.25	IS:3025(P-21)	50 to 500
9	Odour	Agreeable	IS:3025(P-5)	Agreeable
10	Residual Free Chlorine mg/l	0.2	IS:3025(P-26)	Max. 0.5
Biological Water				
1	Coliform per 100 ml	Absent	IS 1622-1981	Max. 10.0
2	Standard Plate count per ml	30 cfu	IS 1622-1981	Max. 100

Test Report No : GTL/03260819053

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method	Specific Requirement as per IS:3328
-------	-------------------------	--------	-------------	-------------------------------------

Remark: In respect of the test performed the submitted sample to the above specification for the parameters tested

CONFORM

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Q.L.=Quantification Limit, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.