

### TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 3

ULR-TC596126700018067F

|                                                                                                                                                                                                                              |                                                                                                                                                        |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Report Issued To :</b> Aksharam Pharma Pvt. Ltd.<br>Plot No : 1 & 2, Akshar Ind, Estate.<br>Opp. Tri Mandir kherali,<br>Surendranagar, Gujarat<br><b>Phone No :</b> 9687500444<br><b>Email :</b> aksharampharma@gmail.com | <b>Test Report No :</b> GTL/03260825030<br><b>Date of Receipt :</b> 19/08/2026<br><b>Date of Issue :</b> 25/08/2026<br><b>Customer's Ref. No :</b> N.M |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|

|                                                                                                                                                                                                                                             |                                                                                                                             |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------|
| <b>Sample Described as :</b> Drinking Water.<br><b>Sample Qty :</b> 10 Ltr + 500 ml<br><b>Packing Mode :</b> Sample Packed in Plastic Container & Sterlie Container<br><b>Sample Condition :</b> Satisfactory<br><b>Marking :</b> Tap Water | <b>Sampling Plan :</b> as per GTL/GP/SOP/055-02<br><b>Sampling Date :</b> 19.08.2026<br><b>Environ. Condition :</b> Ambient |
| <b>Sample Drawn By :</b> Mr. Ramapat Vishwakarma (Representative of Gujarat Testlab Private Limited)<br><b>Sampling Location :</b> Aksharam Pharma Pvt. Ltd.<br><b>Date of Starting of Test :</b> 19/08/2026                                | <b>Date of Completion :</b> 25/08/2026                                                                                      |

| Sr No                 | Test Parameters                              | IS:10500 Requirement (Acceptable Limit) | IS:10500 Permissible Limit in the Absense of Alternate Source | Result    | Q. L.  | Test Method         |
|-----------------------|----------------------------------------------|-----------------------------------------|---------------------------------------------------------------|-----------|--------|---------------------|
| <b>Chemical Water</b> |                                              |                                         |                                                               |           |        |                     |
| 1                     | Colour, Hazen Unit                           | Max 5.0                                 | Max. 15.0                                                     | <1        | 1      | IS:3025(P-4)        |
| 2                     | Odour                                        | Agreeable                               | Agreeable                                                     | Agreeable | --     | IS:3025(P-5)        |
| 3                     | pH at 25 Deg C                               | 6.5 to 8.5                              | No Relaxation                                                 | 6.98      | 1      | IS:3025(P-11)       |
| 4                     | Taste                                        | Agreeable                               | Agreeable                                                     | Agreeable | --     | IS:3025(P-7 & 8)    |
| 5                     | Turbidity, NTU                               | Max. 1.0                                | Max. 5.0                                                      | <0.1      | 0.1    | IS:3025(P-10)       |
| 6                     | Total Dissolved Solids, mg/l                 | Max.500                                 | Max.2000                                                      | 548       | 5      | IS:3025(P-16)       |
| 7                     | Aluminium (as Al) mg/l                       | Max.0.03                                | Max. 0.2                                                      | B.L.Q.    | 0.01   | IS:3025(P-55)       |
| 8                     | Anionic Surface active agents (as MBAS) mg/l | Max. 0.2                                | Max. 1.0                                                      | B.L.Q.    | 0.1    | IS:3025(P-68)       |
| 9                     | Boron (as B) mg/l                            | Max.0.5                                 | Max 1.0                                                       | B.L.Q.    | 0.05   | IS:3025(P-57)       |
| 10                    | Calcium (as Ca), mg/l                        | Max.75                                  | Max.200                                                       | 29.26     | 0.1    | IS:3025(P-40)       |
| 11                    | Chloride (as Cl), mg/l                       | Max.250                                 | Max. 1000                                                     | 163       | 0.5    | IS:3025(P-32)       |
| 12                    | Fluoride (as F) mg/l                         | Max. 1.0                                | Max. 1.5                                                      | B.L.Q.    | 0.01   | IS:3025(P-75)       |
| 13                    | Magnesium (as Mg), mg/l                      | Max. 30                                 | Max. 100                                                      | 17        | 0.1    | IS:3025(P-46)       |
| 14                    | Manganese (as Mn), mg/l                      | Max. 0.1                                | Max. 0.3                                                      | B.L.Q.    | 0.005  | IS:3025(P-65)       |
| 15                    | Mineral Oil mg/l                             | Max. 0.5                                | No Relaxation                                                 | B.L.Q.    | 0.4    | IS:3025(P-39)       |
| 16                    | Nitrate (as NO3) mg/l                        | Max. 45.0                               | No Relaxation                                                 | B.L.Q.    | 1      | IS:3025(P-34)       |
| 17                    | Phenolic Compounds (as C6H5OH) mg/l          | Max. 0.001                              | Max. 0.002                                                    | B.L.Q.    | 0.0001 | IS:3025(P-43) Sec 1 |

Test Report No : GTL/03260825030

| Sr No                                     | Test Parameters                              | IS:10500 Requirement (Acceptable Limit) | IS:10500 Permissible Limit in the Absence of Alternate Source | Result | Q. L.   | Test Method            |
|-------------------------------------------|----------------------------------------------|-----------------------------------------|---------------------------------------------------------------|--------|---------|------------------------|
| 18                                        | Sulphate (as SO <sub>4</sub> ), mg/l         | Max. 200                                | Max. 400                                                      | 8.33   | 1.0     | IS:3025(P-24 Sec-1)    |
| 19                                        | Total Alkalinity as Calcium Carbonate, mg/l  | Max. 200                                | Max. 600                                                      | 177.16 | 0.5     | IS:3025(P-23)          |
| 20                                        | Total Hardness (as CaCO <sub>3</sub> ), mg/l | Max. 200                                | Max. 600                                                      | 132.88 | 0.5     | IS:3025(P-21)          |
| 21                                        | Cyanide (as CN) mg/l                         | Max. 0.05                               | No Relaxation                                                 | B.L.Q. | 0.005   | IS 3025 (P-27) : Sec-1 |
| 22                                        | Residual Free Chlorine mg/l                  | Min. 0.2                                | Max. 1.0                                                      | B.L.Q. | 0.05    | IS:3025(P-26)          |
| 23                                        | Ammonia (as Total Ammonia-N) mg/l            | Max. 0.5                                | No Relaxation                                                 | B.L.Q. | 0.4     | IS:3025(P-34)          |
| 24                                        | Barium (as Ba) mg/l                          | Max. 0.7                                | No Relaxation                                                 | B.L.Q. | 0.5     | Anx-G of IS: 13428     |
| 25                                        | Chloramines (as Cl <sub>2</sub> ) mg/l       | Max. 4.0                                | No Relaxation                                                 | B.L.Q. | 0.05    | IS:3025(P-26)          |
| 26                                        | Sulphide (as H <sub>2</sub> S) mg/l          | Max 0.05                                | No Relaxation                                                 | B.L.Q. | 0.05    | IS:3025(P-29)          |
| <b>Residues and Contaminants in Water</b> |                                              |                                         |                                                               |        |         |                        |
| 27                                        | Copper (as Cu), mg/l                         | Max.0.05                                | Max.1.5                                                       | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 28                                        | Iron (as Fe) mg/l                            | Max. 0.3                                | No Relaxation                                                 | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 29                                        | Selenium (as Se) mg/l                        | Max. 0.01                               | No Relaxation                                                 | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 30                                        | Zinc (as Zn) mg/l                            | Max. 5.0                                | Max. 15.0                                                     | B.L.Q. | 1       | IS:3025(P-49)          |
| 31                                        | Cadmium (as Cd), mg/l                        | Max. 0.003                              | No Relaxation                                                 | B.L.Q. | 0.002   | IS:3025(P-65)          |
| 32                                        | Lead (as Pb), mg/l                           | Max. 0.01                               | No Relaxation                                                 | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 33                                        | Mercury (as Hg) mg/l                         | Max. 0.001                              | No Relaxation                                                 | B.L.Q. | 0.0005  | IS:3025(P-65)          |
| 34                                        | Total Arsenic (as As) mg/l                   | Max. 0.01                               | Max. 0.05                                                     | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 35                                        | Total Chromium (as Cr) mg/l                  | Max. 0.05                               | No Relaxation                                                 | B.L.Q. | 0.01    | IS:3025(P-65)          |
| 36                                        | Silver (as Ag) mg/l                          | Max. 0.1                                | No Relaxation                                                 | B.L.Q. | 0.005   | IS:3025(P-65)          |
| 37                                        | Molybdenum (as Mo) mg/l                      | Max. 0.07                               | No Relaxation                                                 | B.L.Q. | 0.03    | IS:3025(P-65)          |
| 38                                        | Nickel (as Ni), mg/l                         | Max. 0.02                               | No Relaxation                                                 | B.L.Q. | 0.01    | IS:3025(P-65)          |
| 39                                        | Polychlorinated Biphenyls (PCB) mg/l         | Max. 0.0005                             | No Relaxation                                                 | B.L.Q. | 0.00002 | APHA 6630 B            |
| 40                                        | Polynuclear Aromatic Hydrocarbon (PAH) mg/l  | Max. 0.0001                             | No Relaxation                                                 | B.L.Q. | 0.00005 | APHA 6440              |
| 41                                        | Butachlor µg/l                               | Max.125                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 42                                        | Isoproturon µg/l                             | Max.9.0                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 43                                        | Alachlor µg/l                                | Max.20.0                                | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 44                                        | Atrazine µg/l                                | Max. 2.0                                | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 45                                        | Methyl Parathion µg/l                        | Max.0.3                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 46                                        | Malathion µg/l                               | Max.190                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 47                                        | o,p DDE µg/l                                 | Max.1.0                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 48                                        | p,p DDE µg/l                                 | Max.1.0                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 49                                        | o,p DDD µg/l                                 | Max.1.0                                 | Not Relaxation                                                | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 50                                        | p,p DDD µg/l                                 | Max.1.0                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |
| 51                                        | o,p DDT µg/l                                 | Max.1.0                                 | No Relaxation                                                 | B.L.Q. | 0.01    | GL/SOP/I-025           |

Test Report No : GTL/03260825030

| Sr No                   | Test Parameters           | IS:10500 Requirement (Acceptable Limit) | IS:10500 Permissible Limit in the Absence of Alternate Source | Result | Q. L. | Test Method    |
|-------------------------|---------------------------|-----------------------------------------|---------------------------------------------------------------|--------|-------|----------------|
| 52                      | p,p DDT µg/l              | Max.1.0                                 | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 53                      | a HCH µg/l                | Max.0.01                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 54                      | Beta HCH µg/l             | Max.0.04                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 55                      | d HCH µg/l                | Max.0.04                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 56                      | alfa Endosulphan µg/l     | Max. 0.4                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 57                      | Beta endosulphan µg/l     | Max. 0.4                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 58                      | Endosulfan Sulfate µg/l   | Max. 0.4                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 59                      | Monocrotophos µg/l        | Max. 1.0                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 60                      | Ethion µg/l               | Max. 3.0                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 61                      | Lindane µg/l              | Max. 2.0                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 62                      | Chlorpyrifos µg/l         | Max. 30.0                               | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 63                      | Phorate µg/l              | Max. 2.0                                | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 64                      | Aldrin µg/l               | Max. 0.03                               | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 65                      | Dieldrin µg/l             | Max. 0.03                               | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| 66                      | 2,4-D µg/l                | Max. 30                                 | No Relaxation                                                 | B.L.Q. | 0.01  | GL/SOP/I-025   |
| <b>Biological Water</b> |                           |                                         |                                                               |        |       |                |
| 1                       | Total Coliform per 100 ml | Shall not be Detectable                 | Shall not be Detectable                                       | Absent | --    | IS: 15185:2016 |
| 2                       | E.coli per 100 ml         | Shall not be Detectable                 | Shall not be Detectable                                       | Absent | --    | IS: 15185:2016 |

**Remark :** Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar

Reviewed By



For Verification

\*\*\* END OF REPORT \*\*\*

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji-Krishna Amin

Autho. Signatory

**Disclaimer Note**

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.