

TEST REPORT

ULR-TC596126700018476F

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To :	Devasya Super Speciality Kidney & Multi Speciality Hospital (Bopal) 2nd Flor,Samarpan Complex,Bopal Ambli Junction,S.P.Ring Road Bopal Ahmedabad-380058, Ahmedabad, Gujarat Phone No : 9099925496 Email :	Test Report No : GTL/03260902023 Date of Receipt : 27/08/2026 Date of Issue : 02/09/2026 Customer's Ref. No : N.M
--------------------	---	--

Sample Described as	: Drinking Water	Mfg. Date	: N.M.
Sample Qty	: 500 ml	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Container	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: N.M		
Sample Drawn By	: Customer		
Date of Starting of Test	: 27/08/2026	Date of Completion	: 02/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Total Dissolved Solids, mg/l	Max.500	Max.2000	102	5	IS:3025(P-16)

Remark : Sample Found CONFORM as per IS:10500-2012(Acceptable Limit)with Amendment NO-4 for the tested parameter.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Hemal Darji

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.