



TC-5961

F-16,17, Madhavpura Market,
Shahibaug, Ahmedabad-380004

Ph. : 079-25626040, 25624821

M : 7486086091, 9601389681

E : gujlab@gmail.com/gujlab.info@gmail.com

Web : www.gujaratlaboratory.com

ULR-TC596126700018508F

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Jyoti Exports No.110, Vil. Ghambhirpura, Nr.Vavdi Cross Road, Tal-Talod,, Sabarkantha, Gujarat Phone No : 9638750899 Email : jyotiexportsinfo@gmail.com	Test Report No : GTL/03260903001 Date of Receipt : 27/08/2026 Date of Issue : 03/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as Sample Qty Packing Mode Sample Condition Marking Sample Drawn By Date of Starting of Test	: Drinking Water : 2 Ltr : Sample Packed in Plastic Bottle : Satisfactory : Farmer Name : Deepakkumar Jayantibhai Patel,Address : Survey No.1712 VIL.Akrund,Taluka.Dhansura,Dist.Aravalli,Gujarat : Customer : 27/08/2026	Mfg. Date Exp. Date B.No	: N.M. : N.M. : N.M
		Date of Completion	: 03/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.81	1	IS:3025(P-11)
3	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
4	Total Dissolved Solids, mg/l	Max.500	Max.2000	240	5	IS:3025(P-16)
5	Calcium (as Ca), mg/l	Max.75	Max.200	11.51	0.1	IS:3025(P-40)
6	Chloride (as Cl), mg/l	Max.250	Max. 1000	65.3	0.5	IS:3025(P-32)
7	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
8	Magnesium (as Mg), mg/l	Max. 30	Max. 100	7.87	0.1	IS:3025(P-46)
9	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
10	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
11	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	53.38	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260903001

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope

[Signature]
Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

[Signature]
Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

ULR-TC596126700018509F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Jyoti Exports No.110, Vil. Ghambhirpura, Nr.Vavdi Cross Road, Tal-Talod,, Sabarkantha, Gujarat Phone No : 9638750899 Email : jyotiexportsinfo@gmail.com	Test Report No : GTL/03260903002 Date of Receipt : 27/08/2026 Date of Issue : 03/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as Sample Qty Packing Mode Sample Condition Marking Sample Drawn By Date of Starting of Test	: Drinking Water : 2 Ltr : Sample Packed in Plastic Bottle : Satisfactory : Farmer Name : Patel Janeshkumar Ambalal, Address : Survey No.757 VIL.Vadagam Taluka,Dhansura Dist.Aravalli,Gujarat : Customer : 27/08/2026	Mfg. Date Exp. Date B.No	: N.M. : N.M. : N.M
		Date of Completion	: 03/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.78	1	IS:3025(P-11)
3	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
4	Total Dissolved Solids, mg/l	Max.500	Max.2000	220	5	IS:3025(P-16)
5	Calcium (as Ca), mg/l	Max.75	Max.200	11.16	0.1	IS:3025(P-40)
6	Chloride (as Cl), mg/l	Max.250	Max. 1000	67.06	0.5	IS:3025(P-32)
7	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
8	Magnesium (as Mg), mg/l	Max. 30	Max. 100	7.88	0.1	IS:3025(P-46)
9	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
10	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
11	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	50.57	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260903002

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only




For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.