

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700018618F

Page 1 of 1

Report Issued To:	GCS Foundation GCS Medical College, Hospital & Research Centre, Chamunda Flyover Opp DRM Office, Naroda Road, Asarwa, Ahmedabad, Gujarat Phone No : 9727769512 Email : mitul.brahmbhatt@gcsmc.org	Test Report No	: GTL/03260907027
		Date of Receipt	: 01/09/2026
		Date of Issue	: 07/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water	Sampling Plan	: as per GTL/GP/SOP/055
Sample Qty	: 2 Ltr	Sampling Date	: 01.09.2026
Packing Mode	: Sample Packed in Plastic Bottle	Environ. Condition	: Ambient
Sample Condition	: Satisfactory		
Marking	: ICU-01		
Sampling Location	: GCS Foundation		
Sample Drawn By	: Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)		
Date of Starting of Test	: 01/09/2026	Date of Completion	: 07/09/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per USP	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul

Ketul Padhiyar

Reviewed By



For Verification

Trupti Thakor

Trupti Thakor

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

ULR-TC596126700018621F

Report Issued To:	GCS Foundation GCS Medical College, Hospital & Research Centre, Chamunda Flyover Opp DRM Office, Naroda Road, Asarwa, Ahmedabad, Gujarat Phone No : 9727769512 Email : mitul.brahmbhatt@gcsmc.org	Test Report No	: GTL/03260907030
		Date of Receipt	: 01/09/2026
		Date of Issue	: 07/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water	Sampling Plan	: as per GTL/GP/SOP/055
Sample Qty	: 2 Ltr	Sampling Date	: 01.09.2026
Packing Mode	: Sample Packed in Plastic Bottle	Environ. Condition	: Ambient
Sample Condition	: Satisfactory		
Marking	: ICU-02		
Sampling Location	: GCS Foundation		
Sample Drawn By	: Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)		
Date of Starting of Test	: 01/09/2026	Date of Completion	: 07/09/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per Usp	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700018622F

Page 1 of 1

Report Issued To:	GCS Foundation GCS Medical College, Hospital & Research Centre, Chamunda Flyover Opp DRM Office, Naroda Road, Asarwa, Ahmedabad, Gujarat Phone No : 9727769512 Email : mitul.brahmbhatt@gcsmc.org	Test Report No	: GTL/03260907031
		Date of Receipt	: 01/09/2026
		Date of Issue	: 07/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water	Sampling Plan	: as per GTL/GP/SOP/055
Sample Qty	: 2 Ltr	Sampling Date	: 01.09.2026
Packing Mode	: Sample Packed in Plastic Bottle	Environ. Condition	: Ambient
Sample Condition	: Satisfactory		
Marking	: ICU-03		
Sampling Location	: GCS Foundation		
Sample Drawn By	: Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)		
Date of Starting of Test	: 01/09/2026	Date of Completion	: 07/09/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per USP	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

T
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700018623F

Page 1 of 1

Report Issued To:	GCS Foundation GCS Medical College, Hospital & Research Centre, Chamunda Flyover Opp DRM Office, Naroda Road, Asarwa, Ahmedabad, Gujarat Phone No : 9727769512 Email : mitul.brahmbhatt@gcsmc.org	Test Report No	: GTL/03260907032
		Date of Receipt	: 01/09/2026
		Date of Issue	: 07/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water	Sampling Plan	: as per GTL/GP/SOP/055
Sample Qty	: 2 Ltr	Sampling Date	: 01.09.2026
Packing Mode	: Sample Packed in Plastic Bottle	Environ. Condition	: Ambient
Sample Condition	: Satisfactory		
Marking	: Dialysis		
Sampling Location	: GCS Foundation		
Sample Drawn By	: Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)		
Date of Starting of Test	: 01/09/2026	Date of Completion	: 07/09/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological				
Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per USP	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700018624F

Page 1 of 1

Report Issued To:	GCS Foundation GCS Medical College, Hospital & Research Centre, Chamunda Flyover Opp DRM Office, Naroda Road, Asarwa, Ahmedabad, Gujarat Phone No : 9727769512 Email : mitul.brahmbhatt@gcsmc.org	Test Report No	: GTL/03260907034
		Date of Receipt	: 01/09/2026
		Date of Issue	: 07/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water	Sampling Plan	: as per GTL/GP/SOP/055
Sample Qty	: 2 Ltr	Sampling Date	: 01.09.2026
Packing Mode	: Sample Packed in Plastic Bottle	Environ. Condition	: Ambient
Sample Condition	: Satisfactory		
Marking	: ICU-04		
Sampling Location	: GCS Foundation		
Sample Drawn By	: Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)		
Date of Starting of Test	: 01/09/2026	Date of Completion	: 07/09/2026

Sr No	Quality Characteristics	Result	Test Method	Customer Specification
Biological Water				
1	Bacterial Endotoxins Test (Lal Test)	<0.25 EU/ml	As per USP	Max 2.0 EU/ml

Remark: In respect of the test performed the submitted sample to the above specification for the tested parameters.

CONFORM

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.