

TEST REPORT

ULR-TC596126700018647F

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Shivganga Water Suppliers
Shubh-Labh Estate Estate, Opp.
Divya Engineering Tavdipure
Shahibaug-380004, Ahmedabad,
Gujarat
Phone No : 7698111041
Email : kkshab.sba1212@gmail.com

Test Report No : GTL/03260907061
Date of Receipt : 02/09/2026
Date of Issue : 07/09/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 500 ml
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : N.M

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M.

Sample Drawn By : Customer
Date of Starting of Test : 02/09/2026

Date of Completion : 07/09/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Total Coliform per 100 ml	Absent	IS 15185 : 2016
2	E.coli per 100 ml	Absent	IS 15185 : 2016

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti
Trupti Thakor
Autho. Signatory

For NABL Scope

Disclaimer Note

*** END OF REPORT ***

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.