

TEST REPORT

Doc. No : GTL/D/7.5/02

ULR-TC596126700018657F

Page 1 of 1

Report Issued To : Taj Skyline (Engineering Department) Sankalp Square III, Opp. Saket 3, Nr. Nilkanth Green, Sindhubhavan Road, Shilaj, Ahmedabad, Gujarat Phone No : 9773082339 Email : engg.ahmedabad@tajhotels.com	Test Report No : GTL/03260907072 Date of Receipt : 25/08/2026 Date of Issue : 07/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Cooling Tower Water	Mfg. Date : 25.08.2026
Sample Qty : 2 Ltr	Exp. Date : N.M.
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M
Sample Condition : Satisfactory	
Marking : N.M.	
Sample Drawn By : Mr. Vishal Patani (Representative of Gujarat Testlab Private Limited)	
Date of Starting of Test : 25/08/2026	Date of Completion : 07/09/2026

Sr No	Quality Characteristics	Result	Test Method
Biological Water			
1	Legionella/250 ml	Absent	ISO: 11731-2-2017 (E)

Note : NM = Not Mentioned, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Ketul
Ketul Padhiyar
Reviewed By



For Verification

Trupti
Trupti Thakor
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.