

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To :	Gurukrupa Krafts Pvt. Ltd (Factory) A-30, Govardhan township, dhunaimata Mandir Road Nr. Modasa -383315, Aravalli, Gujarat Phone No : 9409677464 Email : purchase.gurukrupakrafts@gmail.com	Test Report No	: GTL/03260910023/NS
		Date of Receipt	: 03/09/2026
		Date of Issue	: 10/09/2026
		Customer's Ref. No	: N.M

Sample Described as	: Water.	Mfg. Date	: N.M.
Sample Qty	: 3x1 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M.
Sample Condition	: Satisfactory		
Marking	: Sample : Feed Water		
Sample Drawn By	: Customer	Date of Completion	: 10/09/2026
Date of Starting of Test	: 03/09/2026		

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Residues and Contaminants in Water			
1	Iron (as Fe) mg/l	11.05	IS:3025(P-65)
Water			
2	Colour	Light Brown Colour Liquid	Visual
3	pH at 25 Deg C	5.95	IS:3025(P-11)
4	Turbidity, NTU	817	IS:3025(P-10)
5	Total Dissolved Solids, mg/l	21450	IS:3025(P-16)
6	Chloride (as Cl), mg/l	2153.50	IS:3025(P-32)
7	Fluoride (as F) mg/l	1.95	IS:3025(P-75)
8	Magnesium (as Mg), mg/l	1461	IS:3025(P-46)
9	Nitrate (as NO3) mg/l	28.45	IS:3025(P-34)
10	Sulphate (as SO4), mg/l	35.60	IS:3025(P-24 Sec-1)
11	Total Alkalinity as Calcium Carbonate, mg/l	6597.50	IS:3025(P-23)
12	Total Hardness (as CaCO3), mg/l	16800	IS:3025(P-21)
13	Residual Free Chlorine mg/l	B.L.Q.(Q.L.=0.05)	IS:3025(P-26)
14	Total Suspended Solids mg/l	65	IS:3025(P-17)
15	Biological Oxygen Demand mg/l	91	IS:3025(P-44)
16	Chemical Oxygen Demand mg/l	280	IS:3025(P-58)
17	Oil & Grease mg/l	0.85	IS:3025(P-39)
18	Reactive Silica (as si) mg/l	0.9	APHA 24th Edition
19	Potassium (as K) mg/l	341.2	IS:3025(P-45)
20	Ammonium (as NH4), mg/l	2.10	APHA 24th Edition

Test Report No : GTL/03260910023/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
21	Calcium (as Ca), mg/l	4617.20	IS : 3025 (P-40):1991
22	Sodium (as Na) mg/l	1362.80	IS:3025(P-45)
23	Non-Reactive Silica mg/l	12.0	IS : 3025 (P-35) : 1988
Biological			
Water			
1	E.coli per 100 ml	Absent	IS:15185:2016
2	Total Bacterial Count cfu/ml	140 cfu	IS:5402 (P-1): 2021

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.