

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 1

Report Issued To : Sarovar Portico Sasan Gir Sasan Junagadh Road,Village-Bhalchhel,Ta : Mendarda,Sasan Gir , Junagadh, Gujarat Phone No : 9601264447 Email :	Test Report No : GTL/03260915018/NS Date of Receipt : 09/09/2026 Date of Issue : 15/09/2026 Customer's Ref. No : N.M
---	---

Sample Described as : ETP Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : N.M.	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 09.09.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Yogesh Shah (Representative of Gujarat Testlab Private Limited) Date of Starting of Test : 09/09/2026	Date of Completion : 15/09/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	7.25	IS:3025(P-11)
2	Total Suspended Solids mg/l	<5	IS:3025(P-17)
3	Biological Oxygen Demand mg/l	<5	IS:3025(P-44)
4	Chemical Oxygen Demand mg/l	<10	IS : 3025 (P-58) : 2003
5	Total Dissolved Solids, mg/l	338	IS:3025(P-16)
6	Oil & Grease mg/l	B.L.Q. (Q.L.=0.5)	IS:3025(P-39)

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***


Hemal Darji
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.