

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018926F

Report Issued To : Cimec Technologics Pvt. Ltd. 23/H, Meldi Estate, Gota,, Ahmedabad, Gujarat Phone No : 9925028369 Email : quality@cimec.in	Test Report No : GTL/03260915024 Date of Receipt : 22/08/2026 Date of Issue : 15/09/2026 Customer's Ref. No : N.M
---	--

Sample Described as	: Drinking Water	Mfg. Date	: N.M.
Sample Qty	: 2 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: Mark : CT/2608200147		
Sample Drawn By	: Customer	Date of Completion	: 15/09/2026
Date of Starting of Test	: 22/08/2026		

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.20	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	597	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	32.32	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	185.68	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	20.45	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	6.28	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	23.88	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	157.44	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915024

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018927F

Report Issued To : Cimec Technologices Pvt. Ltd. 23/H, Meldi Estate, Gota,, Ahmedabad, Gujarat Phone No : 9925028369 Email : quality@cimec.in	Test Report No : GTL/03260915025 Date of Receipt : 10/09/2026 Date of Issue : 15/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Mark : CT/2609080060 Sample Drawn By : Customer Date of Starting of Test : 10/09/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M Date of Completion : 15/09/2026
---	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.02	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	403	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	9.23	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	49.77	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	5.84	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	23.88	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	42.24	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915025

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018928F

Report Issued To : Cimec Technologics Pvt. Ltd.
23/H, Meldi Estate, Gota,, Ahmedabad,
Gujarat
Phone No : 9925028369
Email : quality@cimec.in

Test Report No : GTL/03260915026
Date of Receipt : 10/09/2026
Date of Issue : 15/09/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Mark : CT/2609080059

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M

Sample Drawn By : Customer
Date of Starting of Test : 10/09/2026

Date of Completion : 15/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.93	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	932	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	42.32	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	224.93	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	48.70	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	6.88	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	17.89	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	49.75	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	192.0	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope



Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD



Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018929F

Report Issued To : Cimec Technoligices Pvt. Ltd.
23/H, Meldi Estate, Gota,, Ahmedabad,
Gujarat
Phone No : 9925028369
Email : quality@cimec.in

Test Report No : GTL/03260915027
Date of Receipt : 10/09/2026
Date of Issue : 15/09/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Mark : CT/2609070101

Mfg. Date : N.M.
Exp. Date : N.M.
B.No : N.M

Sample Drawn By : Customer
Date of Starting of Test : 10/09/2026

Date of Completion : 15/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	---	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.45	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	449	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	10.77	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	51.68	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	6.81	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	8.81	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	27.86	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	49.92	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915027

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope



Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD



8.10.20

Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018930F

Report Issued To : Cimec Technologics Pvt. Ltd. 23/H, Meldi Estate, Gota,, Ahmedabad, Gujarat Phone No : 9925028369 Email : quality@cimec.in	Test Report No : GTL/03260915028 Date of Receipt : 12/09/2026 Date of Issue : 15/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water	Mfg. Date : N.M.
Sample Qty : 2 Ltr	Exp. Date : N.M.
Packing Mode : Sample Packed in Plastic Bottle	B.No : N.M
Sample Condition : Satisfactory	
Marking : Mark : CT/2609100163	
Sample Drawn By : Customer	
Date of Starting of Test : 12/09/2026	Date of Completion : 15/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.36	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	603	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	18.46	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	82.31	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	11.68	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	5.65	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	43.78	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	88.32	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915028

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700018931F

Report Issued To : Cimec Technoligices Pvt. Ltd. 23/H, Meldi Estate, Gota,, Ahmedabad, Gujarat Phone No : 9925028369 Email : quality@cimec.in	Test Report No : GTL/03260915029 Date of Receipt : 12/09/2026 Date of Issue : 15/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Mark : CT/2609100164 Sample Drawn By : Customer Date of Starting of Test : 12/09/2026	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M Date of Completion : 15/09/2026
---	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.69	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	152	5	IS:3025(P-16)
7	Anionic Surface active agents (as MBAS) mg/l	Max. 0.2	Max. 1.0	B.L.Q.	0.1	IS:3025(P-68)
8	Calcium (as Ca), mg/l	Max.75	Max.200	10.77	0.1	IS:3025(P-40)
9	Chloride (as Cl), mg/l	Max.250	Max. 1000	21.05	0.5	IS:3025(P-32)
10	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
11	Magnesium (as Mg), mg/l	Max. 30	Max. 100	5.84	0.1	IS:3025(P-46)
12	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
13	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
14	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
15	Total Alkalinity as Calcium Carbonate , mg/l	Max. 200	Max. 600	7.96	0.5	IS:3025(P-23)
16	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	46.08	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03260915029

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
-------	-----------------	---	---	--------	--------------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope



Mamta Bhavsar

Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD



Hemal Darji-Krishna Amin

Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.