

TEST REPORT

ULR-TC596126700019105F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Sterling Hospitals.. Gurukul Ahmedabad-380052 , Ahmedabad, Gujarat Phone No : 9723430990 Email : genequip@sterlinghospitals.com	Test Report No : GTL/03260921030 Date of Receipt : 11/09/2026 Date of Issue : 21/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : R.O.Water	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 11.09.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Satish Dataniya (Representative of Gujarat Testlab Private Limited) Sampling Location : Sterling Hospitals.. Date of Starting of Test : 11/09/2026	Date of Completion : 21/09/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.01	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	95	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	4.90	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	32.54	0.5	IS:3025(P-32)
9	Magnesium (as Mg), mg/l	Max. 30	Max. 100	2.92	0.1	IS:3025(P-46)
10	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
11	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	20.40	1	IS:3025(P-21)
12	Total Alkalinity (as CaCO3) mg/l	Max.200	Max.600	8.12	0.5	IS:3025(P-23)

Test Report No : GTL/03260921030

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***


Hemal Darji
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700019106F

Report Issued To : Sterling Hospitals.. Gurukul Ahmedabad-380052 , Ahmedabad, Gujarat Phone No : 9723430990 Email : genequip@sterlinghospitals.com	Test Report No : GTL/03260921031 Date of Receipt : 11/09/2026 Date of Issue : 21/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Softner Water Sample Drawn By : Mr. Satish Dataniya (Representative of Gujarat Testlab Private Limited) Sampling Location : Sterling Hospitals.. Date of Starting of Test : 11/09/2026	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 11.09.2026 Environ. Condition : Ambient Date of Completion : 21/09/2026
--	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	8.40	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	1348	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	28.61	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	291.93	0.5	IS:3025(P-32)
9	Magnesium (as Mg), mg/l	Max. 30	Max. 100	9.74	0.1	IS:3025(P-46)
10	Sulphate (as SO ₄), mg/l	Max. 200	Max. 400	21.67	0.5	IS:3025(P-24 Sec-1)
11	Total Hardness (as CaCO ₃), mg/l	Max. 200	Max. 600	102.0	1	IS:3025(P-21)
12	Total Alkalinity (as CaCO ₃) mg/l	Max.200	Max.600	56.84	0.5	IS:3025(P-23)

Test Report No : GTL/03260921031

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification


Hemal Darji
Autho. Signatory

*** END OF REPORT ***

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700019108F

Report Issued To : Sterling Hospitals.. Gurukul Ahmedabad-380052 , Ahmedabad, Gujarat Phone No : 9723430990 Email : genequip@sterlinghospitals.com	Test Report No : GTL/03260921033 Date of Receipt : 11/09/2026 Date of Issue : 21/09/2026 Customer's Ref. No : N.M
--	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Raw Water Sample Drawn By : Mr. Satish Dataniya (Representative of Gujarat Testlab Private Limited) Sampling Location : Sterling Hospitals.. Date of Starting of Test : 11/09/2026	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 11.09.2026 Environ. Condition : Ambient Date of Completion : 21/09/2026
--	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	8.47	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	1345	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	69.49	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	301.50	0.5	IS:3025(P-32)
9	Magnesium (as Mg), mg/l	Max. 30	Max. 100	48.70	0.1	IS:3025(P-46)
10	Sulphate (as SO4), mg/l	Max. 200	Max. 400	22.75	0.5	IS:3025(P-24 Sec-1)
11	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	367.20	1	IS:3025(P-21)
12	Total Alkalinity (as CaCO3) mg/l	Max.200	Max.600	60.90	0.5	IS:3025(P-23)

Test Report No : GTL/03260921033

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope



Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***



Hemal Darji
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Sterling Hospitals.. Gurukul Ahmedabad-380052 , Ahmedabad, Gujarat Phone No : 9723430990 Email : genequip@sterlinghospitals.com	Test Report No : GTL/03260921034/NS Date of Receipt : 11/09/2026 Date of Issue : 21/09/2026 Customer's Ref. No : N.M
--	---

Sample Described as : STP Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : STP Inlet Water	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 11.09.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Satish Dataniya (Representative of Gujarat Testlab Private Limited) Date of Starting of Test : 11/09/2026	Date of Completion : 21/09/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	7.29	IS:3025(P-11)
2	Total Suspended Solids mg/l	42	IS:3025(P-17)
3	Biological Oxygen Demand mg/l	12	IS:3025(P-44)
4	Chemical Oxygen Demand mg/l	34	IS : 3025 (P-58) : 2003
5	Oil & Grease mg/l	0.85	IS:3025(P-39)
6	Ammonical nitrogen (NH4-N),mg/l	2.10	APHA 23rd Edition 5530 D
Biological Water			
1	Faecal Coliform MPN/100 ml	<2 MPN	IS:1622:1981

Test Report No : GTL/03260921034/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

Note : NM = Not Mentioned, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Sterling Hospitals.. Gurukul Ahmedabad-380052 , Ahmedabad, Gujarat Phone No : 9723430990 Email : genequip@sterlinghospitals.com	Test Report No : GTL/03260921035/NS Date of Receipt : 11/09/2026 Date of Issue : 21/09/2026 Customer's Ref. No : N.M
--	---

Sample Described as : STP Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : STP Outlet Water	Sampling Plan : as per GTL/GP/SOP/055 Sampling Date : 11.09.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Satish Dataniya (Representative of Gujarat Testlab Private Limited) Date of Starting of Test : 11/09/2026	Date of Completion : 21/09/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical Water			
1	pH at 25 Deg C	7.46	IS:3025(P-11)
2	Total Suspended Solids mg/l	20	IS:3025(P-17)
3	Biological Oxygen Demand mg/l	<5	IS:3025(P-44)
4	Chemical Oxygen Demand mg/l	<10	IS : 3025 (P-58) : 2003
5	Oil & Grease mg/l	B.L.Q.(Q.L.=0.5)	IS:3025(P-39)
6	Ammonical nitrogen (NH ₄ -N),mg/l	B.L.Q.(Q.L.=0.05)	APHA 23rd Edition 5530 D
Biological Water			
1	Faecal Coliform MPN/100 ml	<2 MPN	IS:1622:1981

Test Report No : GTL/03260921035/NS

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only



Mamta Bhavsar

Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD



Hemal Darji-Krishna Amin

Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.