

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700019617F

Report Issued To : Fortune Select S.G Highway
Ahmedabad (Engineer)
Nr.Sola Over Bridge , S.G Highway ,
Ahmedabad, Gujarat
Phone No : 9099937422
Email : chiefengr.fsa@fortunehotels.in

Test Report No : GTL/03261002012
Date of Receipt : 29/09/2026
Date of Issue : 02/10/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : R.O. Water

Sampling Plan : as per GTL/GP/SOP/055-02
Sampling Date : 29.09.2026
Environ. Condition : Ambient

Sample Drawn By : Mr.Vishal Patani(Representative of Gujarat Testlab Private Limited)

Sampling Location : Fortune Select S.G Highway Ahmedabad (Engineer)

Date of Starting of Test : 29/09/2026 **Date of Completion** : 02/10/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.10	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	122	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	4.90	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	34.45	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	3.89	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	24.48	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03261002012

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope



Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***



Hemal Darji-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

ULR-TC596126700019618F

Report Issued To : Fortune Select S.G Highway
Ahmedabad (Engineer)
Nr.Sola Over Bridge , S.G Highway ,
Ahmedabad, Gujarat
Phone No : 9099937422
Email : chiefengr.fsa@fortunehotels.in

Test Report No : GTL/03261002013
Date of Receipt : 29/09/2026
Date of Issue : 02/10/2026
Customer's Ref. No : N.M

Sample Described as : Drinking Water
Sample Qty : 2 Ltr
Packing Mode : Sample Packed in Plastic
Bottle
Sample Condition : Satisfactory
Marking : Soft Water

Sampling Plan : as per GTL/GP/SOP/055-02
Sampling Date : 29.09.2026
Environ. Condition : Ambient

Sample Drawn By : Mr.Vishal Patani(Representative of Gujarat Testlab Private Limited)

Sampling Location : Fortune Select S.G Highway Ahmedabad (Engineer)

Date of Starting of Test : 29/09/2026

Date of Completion : 02/10/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.79	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	1329	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	73.58	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	397.21	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	41.39	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	8.48	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	21.53	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	346.80	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03261002013

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope

Mamta Bhavsar
Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***

Hemal Darji-Krishna Amin
Hemal Darji-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.

TEST REPORT

ULR-TC596126700019619F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Fortune Select S.G Highway Ahmedabad (Engineer) Nr.Sola Over Bridge , S.G Highway , Ahmedabad, Gujarat Phone No : 9099937422 Email : chiefengr.fsa@fortunehotels.in	Test Report No : GTL/03261002014 Date of Receipt : 29/09/2026 Date of Issue : 02/10/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water Sample Qty : 2 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : Raw Water Sample Drawn By : Mr.Vishal Patani(Representative of Gujarat Testlab Private Limited) Sampling Location : Fortune Select S.G Highway Ahmedabad (Engineer) Date of Starting of Test : 29/09/2026	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 29.09.2026 Environ. Condition : Ambient Date of Completion : 02/10/2026
---	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.73	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	1330	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	61.32	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	162.71	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	22.40	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	8.23	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	28.48	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	377.40	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03261002014

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.