

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Majethia Papers Pvt. Ltd. 202,2nd Floor, Corporate House, Opp. Dinesh Hall B/H. Sales India, Near Income tax Circle, Ashram Road-380009, Ahmedabad, Gujarat Phone No : 9825062994 Email : mppl.kalol@gmail.com	Test Report No : GTL/03261003026/NS Date of Receipt : 30/09/2026 Date of Issue : 03/10/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Water. Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : N.M	Mfg. Date : N.M. Exp. Date : N.M. B.No : N.M.
Sample Drawn By : Customer Date of Starting of Test : 30/09/2026	Date of Completion : 03/10/2026

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Residues and Contaminants in Water			
1	Iron (as Fe) mg/I	B.L.Q.(Q.L.=0.005)	IS:3025(P-65)
Water			
2	pH at 25 Deg C	10.36	IS:3025(P-11)
3	Total Dissolved Solids, mg/l	291	IS:3025(P-16)
4	Chloride (as Cl), mg/l	132.08	IS:3025(P-32)
5	Total Hardness (as CaCO ₃), mg/l	4.36	IS:3025(P-21)
6	Total Suspended Solids mg/l	12	IS:3025(P-17)
7	Calcium Hardness (as Ca), mg/l	4.35	IS:3025(P-40)
8	P-Alkalinity mg/l	4.22	IS:3025(P-23)
9	M-Alkalinity mg/l	12.66	IS:3025(P-23)
10	Reactive Silica (as si) mg/l	B.L.Q.(Q.L.=0.05)	APHA 24th Edition
11	Colloidal Silica (as Si) mg/l	B.L.Q.(Q.L.=0.05)	APHA 24th Edition
12	Temparary Hardness mg/l	4.36	AOAC 21st Edition
13	Permanet Hardness mg/l	B.L.Q.(Q.L.=1.0)	AOAC 21st Edition
14	Magnesium Hardness (as Mg), mg/l	4.05	IS:3025(P-46)
15	Phosphate (as PO ₄) mg/l	B.L.Q.(Q.L.=0.05)	IS:3025 (P-31)
16	Sulphite, mg/l	B.L.Q.(Q.L.=0.02)	APHA 23rd Edition

Test Report No : GTL/03261003026/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification,
Q.L.=Quantification Limit, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD


Mamta Bhavsar

Reviewed By



For Verification

*** END OF REPORT ***


Rupesh Desai
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.