

ULR-TC596126700019683F

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Green park Hospitality Services Private Limited IMDC Block, Sargam Marg, IIM, Vastrapur, Pin Code-380015, Ahmedabad, Gujarat Phone No : 9227893709 Email : chefnayak@gmail.com	Test Report No : GTL/03261003055 Date of Receipt : 30/09/2026 Date of Issue : 03/10/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Tap Water Sample Qty : 2.0 Ltr Packing Mode : Sample Packed in Plastic Bottle Sample Condition : Satisfactory Marking : N.M	Sampling Plan : as per GTL/GP/SOP/055-02 Sampling Date : 30.09.2026 Environ. Condition : Ambient
Sample Drawn By : Mr. Ramapat Vishwkarma (Representative of Gujarat TestLab Pvt. Ltd) Sampling Location : Green park Hospitality Services Private Limited Date of Starting of Test : 30/09/2026	Date of Completion : 03/10/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	8.25	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.5	0.5	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	905	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	45.43	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	268.0	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	7.79	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	143.88	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	----	IS 15185 : 2016

Test Report No : GTL/03261003055

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Q. L.	Test Method
-------	-----------------	---	---	--------	-------	-------------

Remark : Sample Found CONFORM as per IS:10500-2012 (Permissible Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification, Customer requested for the above test only

FOR, GUJARAT TESTLAB PVT. LTD



For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

*** END OF REPORT ***


Rupesh Desai-Krishna Amin
Autho. Signatory

Disclaimer Note

(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.