

TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Goran Pharma Pvt. Ltd. G.I.D.C.-1, Bhavnagar Road, Bhavnagar Road, Sihor, Gujarat Phone No : 9925937441 Email : qclab@goranpharma.com	Test Report No : GTL/04260813187/NS Date of Receipt : 08/08/2026 Date of Issue : 13/08/2026 Customer's Ref. No : N.M
---	---

Sample Described as : Personnelle/Option+/Essentiel Sensitive Toothpaste Fresh Mint. Sample Qty : 1 X 100 gm Packing Mode : Sample Packed in Plastic Tube Sample Condition : Satisfactory Marking : Lot No : 0017 Sample Drawn By : Customer Date of Starting of Test : 08/08/2026	Mfg. Date : 08-2026 Exp. Date : 07-2028 B.No : N.M Date of Completion : 13/08/2026
---	---

Sr No	Quality Characteristics	Result	Test Method
Chemical			
Miscellaneous			
1	Fluoride Ion ppm	1093	GL/SOP/C-225
2	Potassium Nitrate %	4.94	In House Specification
3	Sodium Fluoride %	0.2416	GL/SOP/C-226
Biological			
Miscellaneous			
1	Total Aerobic Microbial Count cfu/gm	<10 cfu	AS PER USP
2	E.coli /gm	Absent	AS PER USP
3	Salmonella/10gm	Absent	AS PER USP
4	Yeast & Mould Count cfu/gm	<10 cfu	AS PER USP
5	S.aureus/gm	Absent	AS PER USP
6	Pseudomonas aeruginosa / gm	Absent	AS PER USP
7	Burkholderia cenocepacia / gm	Absent	AS PER USP
8	Burkholderia cepacia / gm	Absent	AS PER USP
9	Burkholderia multivorans / gm	Absent	AS PER USP

Test Report No : GTL/04260813187/NS

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Quality Characteristics	Result	Test Method
-------	-------------------------	--------	-------------

N.A.

Note : NM = Not Mentioned, Customer requested for the above test only


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD


Hemal Darji-Trupti Thakor
Autho. Signatory

Disclaimer Note

*** END OF REPORT ***
(1) The test results relate only to the tested sample(s) and the applicable parameter(s). Endorsement or certification of the product is neither inferred nor implied. (2) This test report shall not be reproduced, either wholly or in part, and shall not be used as evidence in any court of law or for any advertising or promotional purpose without the prior written approval of Gujarat Testlab Private Limited. (3) Customer requested for the above test only. (4) Unless otherwise agreed with the customer or required by a regulatory authority, tested samples will be disposed of after 21 days from the date of issue of the test report. Perishable samples will be destroyed after testing. (5) Samples not drawn by us unless otherwise stated (6) The total liability of the laboratory is limited to the amount invoiced for the testing services. (7) Test reports are issued based on the information and/or data provided by the customer. (8) The accuracy and validity of the test results may be affected if such information or data is incorrect, incomplete, or misleading. (9) Subject to the Ahmedabad Jurisdiction Only.